






To whom it may concern:


Following our visit to Earth Movement Technologies (EMT) on August 16th, 2022. We Allometrics Inc., attest that EMT was certified by one of our technicians under the USP 797 and CETA CAG-009 guidelines for ISO Class 5 “Room(s)”. Please note that the test performed was done under ISO Class 5 specifications, using the required Air Sampler and Sampling equipment. The results of the two samples taken during our visit are listed below:

AeroMetric 797™ Results Summary Sheet

Sample Location	Class	Matrix	Pass	Acpt	O.O.C.	Cause
1: Before/Center/Armrest	5	A				Presence of actionable microorganisms
2: After/Center/Armrest	5	A				
3: TSA Positive Control	NA	A				
4: SDA Positive Control	NA	A				
5: TSA Negative Control	NA	A				
6: SDA Negative Control	NA	A				

-  No growth of microorganisms. Sample in compliance with USP 797 and CAG-009 guidance documents.
-  Growth of microorganisms. Sample in compliance with USP 797 and CAG-009 guidance documents.
-  O.O.C. - Out of Compliance. Unacceptable concentrations or presence of actionable microorganisms.
-  Sample not in compliance with USP 797 and CAG-009 guidance documents.
-  Sample results not applicable to USP 797 and CAG-009 guidance documents.

Sincerely,



Juan S. Hernandez

Account Manager